



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Tuesday, September 18, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY EXTERIOR WALL L.G. STEEL FRAMING AT 6TH FLOOR PARAPET AT FOLLOWING LOCATIONS: FROM D'/13.1 TO D'/19 TO A'/19 TO A'/14; FROM A'/14 TO A'/13.1;

Partial Correction
2 MISC

OK TO COVER WHEN READY EXTERIOR WALL L.G. STEEL FRAMING AT 5TH FLOOR WINDOW BAYS AT FOLLOWING LOCATIONS: FROM D'/13.1 TO D'/19; A'/19 TO A'/13.1;

Comments: