



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121462, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, September 19, 2012
Partial Correction			
1 MISC		OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS	
Corrective Action Required			
2 MISC		REQUEST RE-SPECTION FROM LADDER AFTER TEMPORARY WIRING IS REMOVED	
Gas Piping Inspection - Commercial	John Borns	Partial	Wednesday, September 19, 2012
Corrective Action Required			
1 MISC		IFGC 404.8: ALL EXPOSED METALLIC PIPING MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS.	
Gas Service Inspection - Commercial	John Borns	Passed	Wednesday, September 19, 2012

Comments: RELEASE GAS SERVICE.

