



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121448, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:S, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Wednesday, September 19, 2012

Corrective Action Required
1 MISC

IFGC 404.8: ALL EXPOSED METALLIC PIPING MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS.

Gas Service Inspection - Commercial	John Borns	Passed	Wednesday, September 19, 2012
--	------------	--------	-------------------------------

Comments: RELEASE GAS SERVICE.