



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121996, Building Permit - Commercial
Address: 899 SW LEMANS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mike Copeland	Failed	Thursday, September 20, 2012

Corrective Action Required
1 MISC

6 OUTER COLUMNS REQUIRE 16" DIAMETER x 36"DEEP PIERS.

CALL FOR PIER INSPECTION

POST OCCUPANT LOAD.

NEED TO INSPECT FUTURE ELECTRICAL
OKAY TO USE AREA.

Comments: