

# CITY OF LEE'S SUMMIT

## CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

### PLAN REVIEW CONDITIONS

September 20, 2012

NELSON EDDY CONSTRUCTION LLC  
25410 E STATE ROUTE EE  
HARRISONVILLE, MO 64701

Permit No: PRCOM20122040  
Project Title: ONCE UPON A CHILD  
Project Address: 1131 NE RICE RD, LEES SUMMIT, MO 64086  
Parcel Number: 52810032100000000  
Location: MINOR SUB OF TR A, REPLAT OF LOT 2 DEERBROOK COMMERCIAL PARK LOT 5  
Type of Work: CHANGE OF TENANT  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

#### **Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Approved**

1. 2006 IBC 1109.12.3 - Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required - This will be verified on inspection.

#### **Fire Plan Review**

**Reviewed By: Jim Eden**

**Approved with Conditions**

1. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

The same number shall be posted on the front and rear doors. Verified at inspection.

2. Provide as built for any modifications to the fire sprinkler system during tenant finish or white box.

3. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing sprinkler system shall have documentation of a current annual fire inspection.  
Verified at inspection.

- \_\_\_\_\_ Approved to issue per the listed conditions.
- \_\_\_\_\_ Do not issue per the listed conditions.
- \_\_\_\_\_ Approved to construct foundation only per the listed conditions.
- \_\_\_\_\_ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

\_\_\_\_\_  
Signature of Applicant

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Applicant Name

\_\_\_\_\_  
CompanyName

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***