



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, September 26, 2012
Partial Correction 2 MISC		2-HR BUMP-OUTS AT TUBE COLUMNS AT FREIGHT ELEVATOR WALLS OK TO COVER: FRAMING AND LINER BOARD;	
In-wall Inspection	John Borns	Partial	Wednesday, September 26, 2012
Partial Correction 3 MISC		OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 4F017 THRU 020; 024 THRU 019; 061; 061A THRU 065;	
Rated Assembly Inspection	John Borns	Partial	Wednesday, September 26, 2012
Partial Correction 1 MISC		2-HR BUMP-OUTS AT TUBE COLUMNS AT 3RD & 4TH FLOOR FREIGHT ELEVATOR WALLS OK TO COVER: FRAMING AND LINER BOARD;	

Comments: