



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121047, Building Permit - Commercial
Address: 1720 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, September 26, 2012
Corrective Action Required 1 MISC		HOT/GROUND REVERSE AT TWO ELECT RECEPES @ FRYER	
Corrective Action Required 2 MISC		CHECK/CORRECT WIRING AT ELECT RECEP @ TORTILLIA WARMER	
Corrective Action Required 3 MISC		RE-CHECK ALL CIRCUIT DESIGNATIONS AND AFFIX PERMANENT PANEL SCHEDULES AT ALL PANELS. REFLECT DESIGNATIONS OF ROOFTOP EQUIPMENT.	
Corrective Action Required 4 MISC		SUPPORT COPPER WATER PIPE ABOVE WATER HEATER.	
Corrective Action Required 5 MISC		ROOFTOP ISSUES: - GAS PIPE NOT PAINTED - GAS PIPE SUPPORTS NOT PER DRAWING - IF WOOD BLOCKS ARE ACCEPTABLE TO A/E SECURE SLIP SHEETS TO SIDES OF BLOCKS - ELECT WHIPS @ SOME E/F.'s TOO SHORT - ADDRESS AND DESIGNATE RTU's - DESIGNATE E.F.'s - WORKING ELECT RECEPES WITHIN 10 METERS OF RTU's TO BE VERIFIED	
Corrective Action Required 6 MISC		OK TO SET UP FOR BUSINESS; NO PUBLIC NOR CUSTOMERS	

PRIOR TO APPROVAL

Alarm Test	Joe Dir	Passed	Wednesday, September 26, 2012
Hood/Duct Inspection	Joe Dir	Failed	Wednesday, September 26, 2012
Occupancy Inspection - Fire	Joe Dir	Not Ready	Wednesday, September 26, 2012

Comments: