



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, September 28, 2012

Partial Correction
1 MISC

COMPONENTS OF RATED ASSEMBLIES OK TO COVER AT FOLLOWING LOCATIONS: PHASE 1 COMPLETE.
PHASE 2 SPACES 157; 157A; 159 OK TO TAPE, MUD & FIRE-SEAL 5/8" TYPE X GWB;

Comments: