



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Friday, September 28, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL
SYSTEMS AT FOLLOWING SPACES: 3F012; 4F017 THRU 020; 024
THRU 019; 061; 061A THRU 065;

Rated Assembly Inspection	John Borns	Partial	Friday, September 28, 2012
----------------------------------	------------	---------	----------------------------

Partial Correction
1 MISC

2-HR BUMP-OUTS AT TUBE COLUMNS AT 3RD & 4TH FLOOR
FREIGHT ELEVATOR WALLS OK TO COVER: FRAMING AND
LINER BOARD; + ONE LAYER 5/8" TYPE X GWB

Comments: