



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121791, Building Permit - Commercial
Address: 28 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|--------------|----------|--------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rough Mechanical Inspection - Commercial | Mark Harding | Failed | Monday, October 01, 2012 |

Corrective Action Required
1 MISC

1. FLUE CLEARANCE TO COMUSTIBLES- WOOD ELECTRICAL ETC.
2. MULTIPLE FLUE CONNECTOR PIPE(WYE) shall be dbl wall .
3. PROVIDE GAS PRESSURE TEST.
4. SUPPORT WARDFLEX PER CODE TO WATER HEATERS.
5. EXTEND FLUE AT ROOF TOP TO CORRECT HEIGHT ABOVE ROOF.
6. POS COUNTER SHALL MEET ADA & ANSI 117

Comments: