



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121405, Building Permit - Commercial
Address: 178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Failed	Tuesday, October 02, 2012

Corrective Action Required

1 MISC

FOLLOWING APPROVED TO COVER-
ROOMS SOUTH OF DEMISING WALL AT CORR. 114-
BOTH SIDES OF WALL 114(DEMISING WALL)
108,109.1,110,122,121,123,120,114,112,103,102.

INSTALL STUD GUARDS ON PLUMBING TOP PLATES AND ON
BOTTOM PLATES.
REINFORCE CUT STUDS WHERE PLUMBING IS INSTALLED

Comments: