



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20121791
Address: 28 SE 3RD ST, LEES SUMMIT, MO 64063
Inspected On: Friday, October 05, 2012
Inspected By: Mark HardingMark HardingJoe Dir
Expiration Date: 10/12/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Friday, October 05, 2012
Rough Plumbing Inspection - Commercial	Mark Harding	Passed	Friday, October 05, 2012
Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Friday, October 05, 2012

Corrective Action Required:

1	MISC	open j-box at the ceiling above the elec. panel (storage room) no combustible storage under the staircase (storage room)
---	------	--

Comments: