



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20115216, Building Permit - Residential
Address: 801 NW CEDAR CREEK LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Final - Residential	John Borns	Passed	Monday, October 08, 2012

Comments: LSCO CH 7, ART 10: PERIMETER OF POOL AREA MUST HAVE FENCE OR OTHER BARRIER 48" HIGH MINIMUM. GATES MUST BE SELF-CLOSING AND SELF-LATCHING. ISSUE HAS BEEN REFERRED TO AND IS BEING PURSUED BY LS NHS.