



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20121444, Building Permit - Residential
Address: 713 NW BLACK TWIG LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Failed	Tuesday, October 09, 2012

Corrective Action Required

4 MISC

COMPLETE INSTALLATION OF LIGHT FIXTURES & DEVICES

Corrective Action Required

5 MISC

OPERABLE SMOKE ALARMS REQUIRED IN:

- EACH BEDROOM
- HALLWAY/ALCOVE ADJOINING BEDROOMS

Corrective Action Required

6 MISC

NEC 210-52: ELECT RECEPTACLES AT KITCHEN COUNTERS
MUST BE GFCI-PROTECTED

Corrective Action Required

7 MISC

NEC 210-8; E3802.2: GFCI PROTECTION OF ELECTRICAL
RECEPTACLES: DUPLEX ELECTRICAL RECEPTACLE AT
CLOTHES WASHER NOT GFCI PROTECTED. IF NOT PROTECTED
AND DESIGNATED AS "DEDICATED" FOR WASHER
RECEPTACLE MUST BE SINGLE PLUG.

Corrective Action Required

8 MISC

APPARENT HOT/GROUND REVERSE ON ELECT RECEPT AT LR
W WALL @ S

Corrective Action Required

9 MISC

APPARENT OPEN NEUTRAL ON ELECT RECEPT AT ALCOVE
ADJOINING BEDROOMS

Comments: