



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O. BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122007, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, October 09, 2012
Corrective Action Required 2 MISC		TENSION STUDS NOT SUPPORTED NOR BRACED PER DRAWINGS. SEE 2/A2.0	
Corrective Action Required 5 MISC		IPC 305.8: TWO BOCA PLATES YET TO BE INSTALLED AT BASE TRACK	
Partial Correction 6 MISC		AFTER TWO ADDITIONAL BOCA PLATES ARE IN PLACE OK TO COVER WALLS AND CANOPIES WHEN READY -- EXCEPT DO NOT COVER HANGING STRUCTURE ABOVE SERVING LINE PRIOR TO APPROVAL..	

Comments: