



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121823, Building Permit - Commercial
Address: 620 NW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	John Borns	Partial	Friday, October 19, 2012

Corrective Action Required
1 MISC

NEC 600-3 LISTING/LABELING OF LIGHTED SIGN: INTERNALLY
LIGHTED NOT FOUND TO BE SHOP-LABELED. FIELD-LABELING
ALLOWED ONLY IF WITNESSED AND CERTIFIED BY UL REP.

Comments: NO OTHER ISSUES FOUND ON ELECTRICAL WORK.