



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122007, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, October 23, 2012

Partial Correction
1 MISC

OK TO PROCEED WITH PLUMBING ADDITIONS SHOWN ON
REVISED DRAWING P1.1 USING 1-1/2" PVC DRAIN PIPING IN
LIEU OF 2" WHEREVER ALLOWED BY IPC.

Comments: