



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120184, Building Permit - Commercial  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                                  |            |          |                           |
|----------------------------------|------------|----------|---------------------------|
| Inspection:                      | Inspector: | Outcome: | Date:                     |
| <b>Rated Assembly Inspection</b> | John Borns | Partial  | Tuesday, October 23, 2012 |

Partial Correction  
1 MISC

COMPONENTS OF RATED ASSEMBLIES OK TO COVER AT FOLLOWING LOCATIONS: PHASE 1 COMPLETE; PHASE 2 SPACES 157; 157A; 159 OK TO TAPE, MUD & FIRE-SEAL 5/8" TYPE X GWB; 185 INSIDE & OUTSIDE FACES FULL HEIGHT; 194 FROM 3/C.3 TO A/3.0 TO A/4.0

**Comments:**