



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121319, Building Permit - Commercial
Address: 995 SW 34TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mike Copeland	Failed	Friday, October 26, 2012

Corrective Action Required

1	P305 PROTECTION OF PIPES AND PLUMBING SYSTEM COMPONENTS	PROTECT PLUMBING PIPES WITH PROTECTIVE SHIELD PLATES WHERE LESS THAN 1.5 INCHES FROM THE FACE OF THE STUD. PROTECT WHERE PIPES COME THROUGH THE FLOOR.
---	---	---

Corrective Action Required

2	MISC	SECURE MC CABLE WITHIN 12 INCHES OF THE BOX.
---	------	--

Above Ceiling Inspection	Mike Copeland	Partial	Friday, October 26, 2012
---------------------------------	---------------	---------	--------------------------

Corrective Action Required

1	MISC	OKAY TO INSTALL HARD LID. LEAVE OUT ACCESS TO SEE ACCESS PANELS IN THE DRAFT STOPS.
---	------	---

Above Ceiling Inspection	Mike Copeland	Partial	Friday, October 26, 2012
---------------------------------	---------------	---------	--------------------------

Corrective Action Required

1	MISC	OKAY TO INSTALL HARD LID. LEAVE OUT ACCESS TO SEE ACCESS PANELS IN THE DRAFT STOPS.
---	------	---

Comments:

