



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, October 30, 2012

Partial Correction
1 MISC

2-HR BUMP-OUTS AT TUBE COLUMNS AT 3RD & 4TH FLOOR
FREIGHT ELEVATOR WALLS OK TO COVER: FRAMING AND
LINER BOARD; + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE,
MUD AND FIRE-SEAL

Partial Correction
2 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF
RE-CONSTRUCTION OF RATED WALL AT MECHANICAL SHAFT
@ 4TH FLOOR: FRAMING & SHAFT LINER BOARD; 2 LAYERS 5/8"
TYPE X GWB

Partial Correction
3 MISC

MECHANICAL SHAFT @ 3RD FLOOR: FRAMING + LINER BOARD;
OK TO TAPE, MUD & FIRE-SEAL RATED GWB BOTH FACES @
SPACES 4F036; 037; 040; 082

Comments: