



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121481, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, Unit:220, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, October 30, 2012

Partial Correction
1 MISC

AFTER UNUSED HANGERS ARE REMOVED, ONE INSULATED PIPE RUN SUPPORTED, ALL TEMPORARY ELECTRICAL WIRING IS REMOVED AND ELECT BOXES ARE CLOSED OK TO COVER WHEN READY EXCEPT SPACES 200, 202 AND 204 NOT READY FOR INSPECTION

Comments: