



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, October 31, 2012

Partial Correction
1 MISC

SHAFT WALL CLOSURES AT 6TH FLOOR STAIR SHAFT
OPENINGS ABOVE/BESIDE DOOR OPENINGS 6ASO4A & 6ASO4B
AND KNOCKOUT PANELS FOR FUTURE HOISTWAY
ENTRANCES: OK TO COVER FRAMING + LINER BOARD; 1ST
LAYER 5/8 TYPE X GWB

Comments: