

## CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

## **Inspection Summary**

Permit #: PRCOM20121257, Building Permit - Commercial

Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly John Borns Partial Wednesday, October 31, 2012

Inspection

**Partial Correction** 

1 MISC 2-HR BUMP-OUTS AT TUBE COLUMNS AT 3RD & 4TH FLOOR

FREIGHT ELEVATOR WALLS OK TO COVER: FRAMING AND LINER BOARD: + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE.

MUD AND FIRE-SEAL

**Partial Correction** 

2 MISC OK TO COVER WHEN READY FOLLOWING COMPONENTS OF

RE-CONSTRUCTION OF RATED WALL AT MECHANICAL SHAFT @ 4TH FLOOR: FRAMING & SHAFT LINER BOARD; 2 LAYERS 5/8"

TYPE X GWB

MECHANICAL SHAFT @ 3RD FLOOR: FRAMING + LINER BOARD;

1ST LAYER 5/8" TYPE X GWB

Partial Correction

3 MISC OK TO TAPE, MUD & FIRE-SEAL RATED GWB BOTH FACES @

SPACES 4F036; 037; 040; 082

**Comments:**