



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20122007, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Passed	Thursday, November 01, 2012
<b>Alarm Test</b>	Joe Dir	Passed	Thursday, November 01, 2012

**Comments: OK TO PLACE ACT CEILING TILE WHEN ISSUES POINTED OUT ARE CORRECTED.**