



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, November 01, 2012

Partial Correction
1 MISC

SHAFT WALL CLOSURES AT 6TH FLOOR STAIR SHAFT OPENINGS ABOVE/BESIDE DOOR OPENINGS 6ASO4A & 6ASO4B AND KNOCKOUT PANELS FOR FUTURE HOISTWAY ENTRANCES: OK TO COVER FRAMING + LINER BOARD; 2 LAYERS 5/8 TYPE X GWB

Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, November 01, 2012
--	------------	---------	-----------------------------

Partial Correction
1 MISC

OK TO COVER WHEN READY EXTERIOR WALL L.G. STEEL FRAMING AT 6TH FLOOR PARAPET AT FOLLOWING LOCATIONS: FROM D'/13.1 TO D'/19 TO A'/19 TO A'/14; FROM A'/14 TO A'/13.1; D'/12.9 TO D'/10; D'/10 TO D'/7; A'/5 TO A'/7; A'/1 TO A'/5; D'/7 TO D'/1; A'/1 TO D'/1 EXCLUDING BUMP-OUT YET TO BE FRAMED;

Partial Correction
2 MISC

OK TO COVER WHEN READY EXTERIOR WALL L.G. STEEL FRAMING AT 5TH FLOOR WINDOW BAYS AT FOLLOWING LOCATIONS: FROM D'/13.1 TO D'/19; A'/19 TO A'/13.1; FROM D'/12.9 TO D'/11; A'/5 TO A'/7; A'/5 TO A'/1; D'/8 TO D'/10; D'/7 TO D'/1; A'/1 TO D'/1 EXCLUDING BUMP-OUT YET TO BE FRAMED;

Partial Correction

3 MISC

OK TO COVER WHEN READY L.G. STEEL FRAMING @ 5TH & 6TH FLRS ON (A.6) FROM (19) TO BLDG F

Partial Correction

4 MISC

OK TO COVER WHEN READY 6TH FLOOR LIGHT GAUGE STEEL EXTERIOR WALL FRAMING AT: A'/13.1 TO AA'/10.8 TO AA'/9.3; AA'/9.3 TO A/7

Comments: