



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20122007, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Friday, November 02, 2012

Corrective Action Required

1 MISC

RESOLVE FIRE DEPT ISSUES

Corrective Action Required

2 MISC

ROOFTOP INSPECTION

Corrective Action Required

3 MISC

INSTALLATION OF LIGHTED SIGN SUBJECT TO APPROVAL WHEN INSTALLED. PER NEC 600-3: IF INTERNALLY LIGHTED MUST BE UL SHOP-LABELED PER 600.3. INSTALL NO NON-LISTED SIGN.

Corrective Action Required

4 MISC

PER ICC/ANSI A117.1 SECTION 604.6: WATER CLOSET FLUSH VALVE HANDLE MUST BE AT FREE SIDE OF TANK

Corrective Action Required

5 MISC

IPC 608: BACKFLOW PREVENTION DEVICE REQUIRED AT POTABLE WATER-FED EQUIPMENT. AT CARBONATED BEVERAGE DISPENSING EQUIPMENT USE ASSE 1022 LISTED DEVICE.

Corrective Action Required

6 MISC

APPLY ESCHUTCHEONS AT ALL EXPOSED PLUMBING PENETRATIONS OF WALL AND PARTITIONS.

Corrective Action Required

7 MISC

RESTORE/REPLACE DETERIORATED SUITE LABELS AT RTU's

Corrective Action Required

8 MISC

OK TO SET UP FOR BUSINESS. NO PUBLIC OR CUSTOMERS

PRIOR TO APPROVAL.

**Comments:**