



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Monday, November 12, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY PHASE 2 UNDER-SLAB DWV PIPING AT FOLLOWING LOCATIONS: 107; 184; 185; 188; 189; 191; 191A; 192; 192A; 193; 194E&F; 153; 159; 167;

Comments: