



LEE'S SUMMIT, MISSOURI FIRE DEPARTMENT LOSS REDUCTION PROGRAM



NOTIFICATIONS/CONTACT INFORMATION SECTION

PAGE 1

☐ CHANGES

BUSINESS NAME	ASPEN ATHLETIC CLUB		
ADDRESS	178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081		
OWNER/OPERATOR NAME	DARLAND CONSTRUCTION:	TELEPHONE	(402) 827-8200
ADDRESS	4115 SOUTH 133RD ST OMAHA, NE 68137 Primary: (402) 827-8200 Cell: (913) 568-0769		

EMERGENCY CONTACT INFORMATION

NAME	TELEPHONE
1.	
2.	
3.	
4.	

LOSS REDUCTION TYPE

<input checked="" type="checkbox"/> Occupancy	<input type="checkbox"/> Semi-Annual	<input type="checkbox"/> Annual	<input type="checkbox"/> Life Safety	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Hazardous Material Permit
<input type="checkbox"/> Complaint	<input type="checkbox"/> Explosive Storage	<input type="checkbox"/> UST	<input type="checkbox"/> Post-Incident	<input type="checkbox"/> Open Burning	<input type="checkbox"/> Other alarm system
CLASS: A-4	Map#: 195E	PFA#:	KNOX BOX:	KNOX LOCATION:	PERMIT # PRCOM20121405

LOSS REDUCTION NARRATIVE

☐ NO VIOLATIONS NOTED

☐ ALL VIOLATIONS RESOLVED

Last Inspection

1st Inspection

2nd Inspection

3rd Inspection

4th Inspection

INSPECTION	INSPECTOR	OUTCOME	DATE
Alarm Test	Joe Dir	Passed	Friday, November 16, 2012
Sprinkler - Flow Test	Joe Dir	Partial	Friday, November 16, 2012
Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Friday, November 16, 2012
Corrective Action Required:			
1			
- door access keys to place in the knox box			
- numeric addressing on exterior of all doors			
- label sprinkler room door			
- discontinue all unused wiring A/C wiring and alarm wiring			
- close elec. panel			
- close all open j-boxes			
- remove all const equip, debris, material			
** fire line backflow needs to be assessment and certified			

Sprinkler - Hydrostatic Test

Joe Dir

Passed

Wednesday, November 14,
2012

DATE OF REPORT

November 16, 2012

INSPECTOR

Joe Dir

PREVENTION FOLLOW-UP
REQUIRED?

☒ **Yes**

☐ **No**

RESPONSIBLE SIGNATURE