



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121257, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, November 21, 2012

Partial Correction  
1 MISC

DOGLEGGED RATED WALL ASSEMBLY ABOVE CEILING @ 4F032 SOUTH END - OK TO COVER WHEN READY: FRAMING + LINER BOARD + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL

Partial Correction  
2 MISC

RATED CLOSURES FROM CONCRETE WALLS TO ELEVATOR DOOR FRAMES AT SURGICENTER FOLLOWING COMPONENTS OK TO COVER WHEN READY: 2ND FLOOR OPENINGS -- FRAMING + LINER BOARD + FIRE-CAULK;

<b>In-wall Inspection</b>	John Borns	Partial	Wednesday, November 21, 2012
---------------------------	------------	---------	------------------------------

Partial Correction  
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 3F012; 4F017 THRU 020; 024 THRU 019; 061; 061A THRU 065; 066 thru 070; 072; 045; 075; 042; 074; 075; 076; 016; 034 THRU 041; 031; 032; 033; 016 N END; 4F020 BOTH FACES EXCEPT SE WHERE LATER TO INTERFACE W/ BLDG 100; 022 OUTSIDE FACE WHERE REMOVED FOR MODIFICATIONS AND REPLACED ; 071A; DUPLEX EMERGENCY CIRCUIT ELECT RECEPT ADDED TO HEADWALL @ IC UNITS 4F061 THROUGH 076

**Comments:**