



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20121405
Address: 178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Inspected On: Wednesday, November 21, 2012
Inspected By: John Borns
Expiration Date: 11/29/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Wednesday, November 21, 2012

Corrective Action Required:

1	MISC	RESOLVE ISSUES WITH FIRE DEPARTMENT AND WATER DEPARTMENT
---	------	--

Corrective Action Required:

8	MISC	PROVIDE ELECTRICAL RECEPTACLE WITHIN 10 METERS OF RTU'S #11 AND #12
---	------	---

Corrective Action Required:

9	MISC	NO CLAMPS AT THREE SUPPORTS FOR GAS PIPING TO RTU #12
---	------	---

Corrective Action Required:

10	MISC	PHASE 1 AREA IMPROVEMENT WAS PERMITTED, INSPECTED, AND APPROVED FOR TEMPORARY USE ONLY PENDING COMPLETION OF MAIN AREA ENCOMPASSED BY THIS PERMIT SCOPE. NOT APPROVED FOR PERMANENT USE.
----	------	--

Comments: