



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, November 28, 2012

Partial Correction
1 MISC

DOGLEGGED RATED WALL ASSEMBLY ABOVE CEILING @ 4F032 SOUTH END - OK TO COVER WHEN READY: FRAMING + LINER BOARD + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL

Partial Correction
2 MISC

RATED CLOSURES FROM CONCRETE WALLS TO ELEVATOR DOOR FRAMES AT SURGICENTER FOLLOWING COMPONENTS OK TO COVER WHEN READY:
2ND FLOOR OPENINGS -- FRAMING + LINER BOARD + FIRE-CAULK + 1ST LAYER 5/8" TYPE X GWB;

1ST FLOOR OPENINGS -- FRAMING + LINER BOARD

Comments: