



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120184, Building Permit - Commercial  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Friday, November 30, 2012

Corrective Action Required  
1 MISC

FOLLOWING PHASES/SPACES OK FOR TEMPORARY  
OCCUPANCY & USE: PHASE 1; PHASE 2F;

RESOLVE ANY ISSUES WITH FIRE DEPARTMENT

Corrective Action Required  
3 MISC

SPACES NOT READY FOR FINAL INSPECTION:  
- OR#4  
- ROOFTOPS (SOME WORK NOT COMPLETED)

Corrective Action Required  
4 MISC

ROOFTOPS:  
- IFGC 404.8: EXPOSED METALLIC PIPING MUST BE  
PERMANENTLY PROTECTED WITH PAINT OR BY OTHER  
APPROVED MEANS.

- FINAL CLEANUP: REMOVE ALL DEBRIS AND UNUSED  
MATERIAL

Corrective Action Required  
5 MISC

PHASE 2A AREA OK TO SET UP FOR BUSINESS; NO PATIENTS  
NOR PUBLIC PRIOR TO APPROVAL

**Comments:**