



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, December 05, 2012

Corrective Action Required
1 MISC

FOLLOWING PHASES/SPACES OK FOR TEMPORARY
OCCUPANCY & USE: PHASE 1; PHASE 2F;

RESOLVE ANY ISSUES WITH FIRE DEPARTMENT

Corrective Action Required
3 MISC

ROOFTOPS:

- IFGC 404.8: EXPOSED METALLIC PIPING MUST BE
PERMANENTLY PROTECTED WITH PAINT OR BY OTHER
APPROVED MEANS.

- FINAL CLEANUP: REMOVE ALL DEBRIS AND UNUSED
MATERIAL

Partial Correction
4 MISC

PHASES 2A & 2D AREAS OK TO SET UP FOR BUSINESS; NO
PATIENTS NOR PUBLIC PRIOR TO APPROVAL

Corrective Action Required
5 MISC

MED GAS PIPING TEST CERTS REQUIRED FOR PHASE 2D AREA
FOR TCO STATUS TO BE APPROVED

Comments: