

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600 PHONE: 816-969-1200

FAX: 816-969-1201

Inspection Summary

Permit #: PRCOM20122279, Building Permit - Commercial Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Friday, December 07, 2012
Partial Correction 1 MISC	POUF INTE WALI SW C EAST	R WHEN READY SECT GRAL COLUMN FOOTIN L; EAST WALL N 15'; S CORNER TO ELEVATOR WALL; ON (A) FROM (JUMPER IS CONNECTED OK TO IONS OF CONCRETE GRADE BEAM + NGS DESCRIBED BELOW: NORTH WALL EXCEPT E 10'; W WALL FROM R PIT; FROM S WALL ~1/B CCW ON (9) TO (13) TO COMPLETE EAST R PIT, THEN TO NE CORNER
Partial Correction 2 MISC Partial Correction 3 MISC Partial Correction 4 MISC	ENSURE FULL 3" RE-BAR COVERAGE AT BOTTOMS AND E		OVERAGE AT BOTTOMS AND BANKS
	OK TO POUR WHEN READY ISOLATED COLUMN FOOTINGS AT FOLLOWING LOCATIONS: 9/B; 9/D; 9/F; 5/F; 3/F; G/2; H/5; B/4; D/4; F/6;		
Concrete Walls and Columns Inspection	John Borns	Partial	Friday, December 07, 2012
Partial Correction			

1 MISC

OK TO POUR WHEN READY C.I.P. CONCRETE WALLS & INTEGRAL PILASTERS AT FOLLOWING LOCATIONS: ON (13) FROM (B) TO (H); ON (J) FROM (1) TO (2.2); ON (1) FROM (A) TO Comments: