



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121481, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, Unit:220, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Monday, December 10, 2012

Corrective Action Required
1 MISC

APPROVED ELEVATOR INSPECTION CERTIFICATE REQUIRED
BEFORE ADMISSION OF PATIENTS AND PUBLIC

Corrective Action Required
2 MISC

PROVIDE MANUFACTURER DOCUMENTATION THAT AQUAPURE
UNIT HAS BACKFLOW PREVENTION BUILT IN -- OR INSTALL
DEVICE IN POTABLE WATER FEED LINE.

Partial Correction
3 MISC

OCCUPANCY STATUS: OK TO SET UP FOR OPERATION. NO
PUBLIC NOR PATIENTS PRIOR TO APPROVAL.

Alarm Test	Joe Dir	Passed	Monday, December 10, 2012
-------------------	---------	--------	---------------------------

Sprinkler - Hydrostatic Test	Joe Dir	Passed	Monday, December 10, 2012
---	---------	--------	---------------------------

Sprinkler - Flow Test	Joe Dir	Passed	Monday, December 10, 2012
----------------------------------	---------	--------	---------------------------

**Occupancy
Inspection - Fire**

Joe Dir

Passed

Monday, December 10, 2012

Comments: