



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, December 10, 2012

Partial Correction
1 MISC

SHAFT WALL CLOSURES AT 6TH FLOOR STAIR SHAFT OPENINGS ABOVE/BESIDE DOOR OPENINGS 6ASO4A & 6ASO4B AND KNOCKOUT PANELS FOR FUTURE HOISTWAY ENTRANCES: OK TO COVER FRAMING + LINER BOARD; 2 LAYERS 5/8 TYPE X GWB WITH JOINTS MUDDED AND PERIMETER FIRE-CAULKED

Partial Correction
2 MISC

2-HR FIRESTOPPING PER DETAIL SECTION 21/A6.3 AT ROOF LEVEL ON (B') FROM (19) TO 12' NORTH

Partial Correction
3 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED LID @ SOUTH ELEVATOR HOISTWAY: FRAMING + LINER BOARD + FIRE CAULK; 2 LAYERS OF 5/8" TYPE X GWB WITH PERIMETER FIRE CAULKED

RATED LID @ NORTH ELEVATOR HOISTWAY: FRAMING + LINER BOARD WITH PERIMETER FIRE CAULKED;

Comments: