



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121319, Building Permit - Commercial  
Address: 995 SW 34TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mike Copeland	Partial	Thursday, December 13, 2012

Partial Correction  
1 MISC

OKAY TO INSTALL HARD LID. LEAVE OUT ACCESS TO SEE ACCESS PANELS IN THE DRAFT STOPS.

TOP ROUGH PLUMBING APPROVED AT EAST PATIENT AREA.

EXTERIOR SOFFITS APPROVED TO COVER

VESTIBULE NORTH CANS APPROVED

EXAM ROOMS, TWO BATHROOMS MIDDLE AND SOUTH OF BUILDING OKAY TO DROP TILE

**Comments:**