



MISSOURI DIVISION OF FIRE SAFETY
ELEVATOR SAFETY UNIT

P.O. BOX 844
JEFFERSON CITY, MO 65102
573-751-2930 FAX: 573-526-5971

APPLICATION/INSPECTION

NOTE: ONE APPLICATION/FORM MUST BE SUBMITTED FOR EACH UNIT OF EQUIPMENT

File: PRCDM20121481

☒ INSPECTION

☐ VARIANCE

DATE

STATE ID

12/13/12 21337

OWNER NAME ST. Lukes		OWNER ADDRESS 100 NE ST Lukes Blvd		OWNER CITY, STATE, ZIP Leas Summit MO 64086	
BILLING NAME (IF DIFFERENT FROM OWNER)		BILLING ADDRESS		BILLING CITY, STATE, ZIP	
LOCATION NAME		LOCATION ADDRESS		LOCATION CITY, STATE, ZIP	
LOCATION COUNTY JACKSON		LOCATION PHONE 816-347-5000		NUMBER OF UNITS AT LOCATION	
ACTIVITY		TYPE OF EQUIPMENT		BUILDING USAGE	
☒ NEW INSTALLATION		☐ PASSENGER-TRACTION		☐ OFFICE/GOVT BUILDING	
☐ ALTERATION		☒ PASSENGER-HYDRAULIC		☒ HOSPITAL/INSTITUTIONAL	
☐ MAJOR ALTERATION		☐ PASSENGER-ROPED HYDRAULIC		☐ CHURCH/RELIGIOUS	
☐ INITIAL INSPECTION		☐ FREIGHT-TRACTION		☐ COMMERCIAL/INDUSTRIAL	
☐ ANNUAL INSPECTION		☐ FREIGHT-HYDRAULIC		☐ RETAIL	
☐ TEMPORARY CERTIFICATE INSP		☐ FREIGHT-ROPED HYDRAULIC		☐ SCHOOL/LIBRARY/EDUCATIONAL	
☐ REINSPECTION		☐ DUMBWAITER		☐ PARKING GARAGE	
☐ 5-YR TEST		☐ ESCALATOR		☐ MULTI/FAMILY RESIDENCE	
☐ OTHER		☐ MANLIFT		☐ MOTEL/HOTEL	
☐ SPECIAL		☐ STAIRWAY LIFT		☐ BANK	
		☐ MATERIAL LIFT		☐ NURSING/RETIREMENT HOME	
		☐ MOVING SIDEWALK		☐ OTHER	
		☐ OTHER			
MANUFACTURER Kone		DATE INSTALLED 2012		CAPACITY 3500	
SERIAL NUMBER 2034717		SPEED 150			
NUMBER OF LANDINGS 2		NO. OF OPENINGS (FRONT/REAR) 2		SPECIFIC LOCATION IN BUILDING OR ID Sug. ctr #2	
DATE OF 5-YEAR TEST		DATE OF LAST TEST			
RELIEF VALVE PRESSURE		SLIDE 5 3/4"		GOV ROPE PULL OUT/PULL THRU 190	
				DOOR CLOSING FORCE 15	
DESCRIPTION OF VIOLATION OR VARIANCE: (IF APPLICABLE)				COMPLIANCE DATE	
No violations OK to use.					
WRITTEN RESPONSE REQUIRED WHEN COMPLIANCE IS COMPLETED					
SIGNATURE OF CONTACT PERSON AT LOCATION Adam W. Whitcomb			INSPECTOR SIGNATURE Boyd Edwards		
PRINTED NAME AND TITLE OF CONTACT PERSON AT LOCATION Adam W. Whitcomb, Superintendent			INSPECTOR STATE ID #237		