



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O. BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121010, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, December 17, 2012

Partial Correction  
1 MISC

2-HR FIRESTOPPING PER DETAIL SECTION 21/A6.3 AT ROOF LEVEL ON (B') FROM (19) TO 12' NORTH

Partial Correction  
2 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED LID @ SOUTH ELEVATOR HOISTWAY: FRAMING + LINER BOARD + FIRE CAULK; 2 LAYERS OF 5/8" TYPE X GWB WITH PERIMETER FIRE CAULKED

RATED LID @ NORTH ELEVATOR HOISTWAY: FRAMING + LINER BOARD WITH PERIMETER FIRE CAULKED; TWO LAYERS 5/8" TYPE X GWB

**Comments:**