



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, December 19, 2012

Partial Correction
1 MISC

DOGLEGGED RATED WALL ASSEMBLY ABOVE CEILING @ 4F032 SOUTH END - OK TO COVER WHEN READY: FRAMING + LINER BOARD + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL

Partial Correction
2 MISC

RATED CLOSURES FROM CONCRETE WALLS TO ELEVATOR DOOR FRAMES AT SURGICENTER 1ST & 2ND FLOOR OPENINGS COMPLETE

Partial Correction
3 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED BUMP-OUTS AT 5TH FLOOR ELEVATOR SHAFT WALLS -- ONE @ S WALL + TWO @ N WALL: FRAMING + LINER BOARD FIRE-CAULKED

Partial Correction
4 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF 5TH FLOOR RATED UTILITY SHAFT WALL: FRAMING + LINER BOARD FIRE-CAULKED;

In-wall Inspection	John Borns	Partial	Wednesday, December 19, 2012
---------------------------	------------	---------	------------------------------

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 3F012; 4F017 THRU 020; 024

THRU 019; 061; 061A THRU 065; 066 thru 070; 072; 045; 075; 042;
074; 075; 076; 016; 034 THRU 041; 031; 032; 033; 016 N END; 4F020
BOTH FACES EXCEPT SE WHERE LATER TO INTERFACE W/
BLDG 100; 022 OUTSIDE FACE WHERE REMOVED FOR
MODIFICATIONS AND REPLACED ; 071A; DUPLEX EMERGENCY
CIRCUIT ELECT RECEPT ADDED TO HEADWALL @ IC UNITS
4F061 THROUGH 076; 071 SE;

**Above Ceiling
Inspection**

John Borns

Partial

Wednesday, December 19, 2012

Partial Correction

1 MISC

OK TO COVER WHEN READY GWB CEILING FRAMING AND
ABOVE-CEILING SYSTEMS AT: 3F012; SHOWERS AT 061-065;
NURSE WORK STATIONS IN CORRIDOR 031; SOFFITS @ INNER
ARC OF CORRIDORS 4F016, 031, 034/035, 041; ARC SOFFITS @
ENDS OF CORRIDORS 4F031/034 & 041; TRIANGULAR SEGMENT
IN CORR 021 S OF SE CORNER OF FREIGHT ELEVATOR SHAFT;

Partial Correction

2 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 4F017; 018;
023 THRU 030; 061/061A THRU 064/064A; 065B THRU 070/070A;
035; 042; 043; 036; 038; 039; 040; 072; 073/073A; 074; 076;

Comments: