



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20122126, Building Permit - Residential
Address: 301 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	John Borns	Failed	Wednesday, December 19, 2012

Corrective Action Required
1 MISC

LSCO 7-608: GAS PIPING TEST PRESSURE DECREASED DURING MONITORING PERIOD. PRESSURIZE PIPING SYSTEM TO HOLD STEADY AT MINIMUM 10 PSI

Electrical Service Inspection - Residential	John Borns	Partial	Wednesday, December 19, 2012
------------------------------------------------------------	------------	---------	------------------------------

Corrective Action Required
1 MISC

ONE GROUND ROD INSTALLED, BUT EXISTING WATER LINE GROUND NEEDS TO BE EXTENDED AND TERMINATED AT PANEL. SERVICE RELEASED ON TEMPORARY BASIS.

Comments: