



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, December 28, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY GWB CEILING FRAMING AND ABOVE-CEILING SYSTEMS AT: 3F012; SHOWERS AT 061-065; NURSE WORK STATIONS IN CORRIDOR 031; SOFFITS @ INNER ARC OF CORRIDORS 4F016, 031, 034/035, 041; ARC SOFFITS @ ENDS OF CORRIDORS 4F031/034 & 041; TRIANGULAR SEGMENT IN CORR 021 S OF SE CORNER OF FREIGHT ELEVATOR SHAFT;

Partial Correction
2 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 4F017; 018; 023 THRU 030; 035; 036; 038; 039; 040; 042; 043; 061/061A THRU 064/064A; 065B THRU 070/070A; 072; 073/073A; 074; 076; [*015; 016; 022; 031; 034; 037; 041; 071A; 072A; 074A; 075A; 076A*];

*LUMINAIRES ON ORDER TO BE INSTALLED WHEN RECEIVED

Rated Assembly Inspection	John Borns	Partial	Friday, December 28, 2012
----------------------------------	------------	---------	---------------------------

Partial Correction
1 MISC

DOGLEGGED RATED WALL ASSEMBLY ABOVE CEILING @ 4F032 SOUTH END - OK TO COVER WHEN READY: FRAMING + LINER BOARD + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL

Partial Correction
2 MISC

RATED CLOSURES FROM CONCRETE WALLS TO ELEVATOR
DOOR FRAMES AT SURGICENTER 1ST & 2ND FLOOR OPENINGS
COMPLETE

Partial Correction
3 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF
RATED BUMP-OUTS AT 5TH FLOOR ELEVATOR SHAFT WALLS --
ONE @ S WALL + TWO @ N WALL: FRAMING + LINER BOARD
FIRE-CAULKED; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE,
MUD, & FIRE-SEAL

Partial Correction
4 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF
5TH FLOOR RATED UTILITY SHAFT WALL: FRAMING + LINER
BOARD FIRE-CAULKED; TWO LAYERS 5/8" TYPE X GWB OK TO
TAPE, MUD, & FIRE-SEAL

Comments: