



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20122763, Building Permit - Commercial  
Address: 809 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Commercial</b>	John Borns	Passed	Friday, December 28, 2012
<b>Final Plumbing Inspection - Commercial</b>	Mark Harding	Passed	Friday, December 28, 2012

**Comments: GAS PIPING PRESSURE TEST HELD STEADY AT  $\geq 10$  PSI FOR  $\geq 10$  MIN.  
RELEASE GAS SERVICE. CLOSE PERMIT.**