



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121736, Building Permit - Commercial
Address: 901 SE LANGSFORD RD, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Partial	Thursday, January 03, 2013

Partial Correction
1 MISC

OKAY TO DROP EVERYWHERE EXCEPT WHERE MC COMES
THROUGH CEILING FOR CASH REGISTERS

Comments: