



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Thursday, January 03, 2013

Partial Correction
1 MISC

DOGLEGGED RATED WALL ASSEMBLY ABOVE CEILING @ 4F032 SOUTH END - OK TO COVER WHEN READY: FRAMING + LINER BOARD + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL

Partial Correction
2 MISC

RATED CLOSURES FROM CONCRETE WALLS TO ELEVATOR DOOR FRAMES AT SURGICENTER 1ST & 2ND FLOOR OPENINGS COMPLETE

Partial Correction
3 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED BUMP-OUTS AT 5TH FLOOR ELEVATOR SHAFT WALLS -- ONE @ S WALL + TWO @ N WALL: FRAMING + LINER BOARD FIRE-CAULKED; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD, & FIRE-SEAL

Partial Correction
4 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF 5TH FLOOR RATED UTILITY SHAFT WALL: FRAMING + LINER BOARD FIRE-CAULKED; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD, & FIRE-SEAL

Partial Correction
5 MISC

2ND, 3RD AND 4TH CORE BOARD AROUND ELEVATOR DOORS APPROVED 1ST LAYER.

Comments: