



# LEE'S SUMMIT, MISSOURI FIRE DEPARTMENT LOSS REDUCTION PROGRAM



## NOTIFICATIONS/CONTACT INFORMATION SECTION

PAGE 1

### ☐ CHANGES

|                            |  |                  |                    |
|----------------------------|--|------------------|--------------------|
| <b>BUSINESS NAME</b>       | ARNOLD HALL  |                  |                    |
| <b>ADDRESS</b>             | 123 SE 3RD ST, LEES SUMMIT, MO 64063   |                  |                    |
| <b>OWNER/OPERATOR NAME</b> | CITY OF LEES SUMMIT:   | <b>TELEPHONE</b> | <NO PRIMARY PHONE> |
| <b>ADDRESS</b>             | PO BOX 1600<br>LEES SUMMIT, MO 64063--7600<br>Primary: <NO PRIMARY PHONE><br>Cell: <NO CELL PHONE> Steve Aldridge @ 816-969-1205 |                  |                    |

## EMERGENCY CONTACT INFORMATION

| NAME | TELEPHONE |
|------|-----------|
| 1.   |           |
| 2.   |           |
| 3.   |           |
| 4.   |           |

## LOSS REDUCTION TYPE

|                                    |  |                                 |  |   |  |
|------------------------------------|--|---------------------------------|--|---|--|
| <input type="checkbox"/> Occupancy | <input type="checkbox"/> Semi-Annual       | <input type="checkbox"/> Annual | <input type="checkbox"/> Life Safety   | <input checked="" type="checkbox"/> Sprinkler | <input type="checkbox"/> Hazardous Material Permit |
| <input type="checkbox"/> Complaint | <input type="checkbox"/> Explosive Storage | <input type="checkbox"/> UST    | <input type="checkbox"/> Post-Incident | <input type="checkbox"/> Open Burning         | <input type="checkbox"/> Other                     |
| CLASS:<br>UC                       | Map#:<br>195G                              | PFA#:                           | KNOX BOX:                              | KNOX LOCATION:                                | PERMIT #<br>PRCOM20122128                          |

## LOSS REDUCTION NARRATIVE

### ☐ NO VIOLATIONS NOTED

### ☐ ALL VIOLATIONS RESOLVED

Last Inspection      1st Inspection 1/7/13      2nd Inspection      3rd Inspection      4th Inspection

| INSPECTION   | INSPECTOR                   | OUTCOME  | DATE                         |
|--|-----------------------------|--|------------------------------|
| <b>Sprinkler - Hydrostatic Test</b>  | Joe Dir                     | Passed   | Monday, January 07, 2013     |
| Corrective Action Required:<br>1      PRCOM20122128 hydrostatic test: system held test pressure at 210psi for required test period of 2 hours. Testing the flow alarm, it was noticed that the wires for the outside flow alarm bell had been cut and removed. The outside flow alarm needs to be restored to working order. |                             |  |                              |
| <b>DATE OF REPORT</b><br>January 07, 2013  | <b>INSPECTOR</b><br>Joe Dir | <b>PREVENTION FOLLOW-UP REQUIRED?</b><br><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <b>RESPONSIBLE SIGNATURE</b> |