

Sprinkler - Hydrostatic Test



Thursday, December 06, 2012

## LEE'S SUMMIT, MISSOURI FIRE DEPARTMENT LOSS REDUCTION PROGRAM

	NOTIFICATIONS/C	ONTACT INFORMAT	ION SECTION	PAGE 1		
☐ CHANGES						
BUSINESS NAME	BIG LOTS					
ADDRESS	901 SE LANGSFORD RD, LEES SUMMIT, MO 64063					
OWNER/OPERATOR NAME	ALLIED RETAIL CONCEP	TS LLC:	TELEPHONE	(913) 492-8008		
ADDRESS	6205 GODDARD ST SHAWNEE, KS 66203 Primary: (913) 492-8008 Cell: (816) 365-6153 Jord	lan @ 913-707-4489				
EMERGENCY CONTACT INFORMATION						
NAME	TELEPHONE					
1.						
2.						
3.						
4.						
LOSS REDUCTION TYPE						
	<b></b>			Hazardous Material		
⊠ Occupancy    □ Sen	ni-Annual	☐ Life Safety	☐ Sprinkler ☐	Permit		
<u> </u>	losive Storage  UST	Post-Incident	Open Burning	<del> </del>		
	Map#: PFA#: 195H	KNOX BOX:	KNOX LOCATION:	PERMIT # PRCOM20121736		
LOSS REDUCTION NARRATIVE						
□ NO VIOLATIONS NOTED □ ALL VIOLATIONS RESOLVED						
		_	rd Inspection	4th Inspection		
INSPECTION	INSPECTOR	OUTCOME	DATE			
Occupancy Inspection			y C of O Monday, Jar	nuary 14, 2013		
Corrective Action Required:  - restore the fire department connection for the sprinkler system back to working order.  - need access keys for the store. (to lock in the knox box)  - label the access door for the sprinkler room on the sales side of the door  - lower sprinkler heads below the drop ceiling as needed located at the rear of the sales area  - replace exterior water flow bell with a weatherproof horn/strobe  - address exterior of the double doors to receiveing ( southwest double doors) with numeric address of 901						
Alarm Test	Joe Dir	Passed	Monday, Jar	nuary 14, 2013		

Not Required

Sprinkler - Flow Test	Joe Dir	Failed Mond	ay, January 14, 2013
DATE OF REPORT	INSPECTOR	PREVENTION FOLLOW-UP REQUIRED?	RESPONSIBLE SIGNATURE
January 14, 2013	Joe Dir	⊠Yes □ No	