



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|------------|----------|---------------------------|
| Rated Assembly Inspection | John Borns | Partial | Tuesday, January 15, 2013 |

Partial Correction
5 MISC

FOLLOWING COMPONENTS OF PASSENGER ELEVATOR
FRONTS OK TO COVER WHEN READY :

1ST FLOOR: FRAMING, LINER BOARD + FIRE CAULK;

3RD, 5TH FLOORS: FRAMING, LINER BOARD + FIRE CAULK; ONE
LAYER 5/8" TYPE X GWB FIRE-CAULKED;

Partial Correction
6 MISC

FOLLOWING COMPONENTS OF 1ST FLOOR FREIGHT ELEVATOR
SHAFT OK TO COVER WHEN READY: FRAMING, LINER BOARD +
FIRE CAULK;

Partial Correction
7 MISC

FOLLOWING COMPONENTS OF FREIGHT ELEVATOR FRONTS
OK TO COVER WHEN READY:
2ND FLOOR THROUGH 5TH FLOOR: FRAMING, LINER BOARD +
FIRE CAULK;

| | | | |
|---|------------|---------|---------------------------|
| Underslab Plumbing Inspection - Commercial | John Borns | Partial | Tuesday, January 15, 2013 |
|---|------------|---------|---------------------------|

Partial Correction
1 MISC

OK TO COVER WHEN READY UNDER-SLAB C.I. DWV PIPING @

SPACE 1A092

Comments: