



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121864, Building Permit - Commercial
Address: 400 SW LONGVIEW BLVD, Unit:160, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Passed	Wednesday, January 16, 2013
Final Electrical Inspection - Commercial	Mark Harding	Passed	Wednesday, January 16, 2013

Comments: