

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial

Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

In-wall Inspection John Borns Partial Friday, January 18, 2013

Partial Correction

1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 3F012; 4F017 THRU 020; 024 THRU 019; 061; 061A THRU 065; 066 thru 070; 072; 045; 075; 074; 075; 076; 016; 034 THRU 041; 031; 032; 033; 016 N END; 4F020 BOTH FACES EXCEPT SE WHERE LATER TO INTERFACE W/BLDG 100; 022 OUTSIDE FACE WHERE REMOVED FOR

MODIFICATIONS AND REPLACED; 071A; DUPLEX EMERGENCY CIRCUIT ELECT RECEPT ADDED TO HEADWALL @ IC UNITS 4F061 THROUGH 076; 071 SE; PASSENGER ELEVATOR

ENTRANCES AT 2ND & 4TH FLOORS; WALL + DOOR FRAME @

4F021 SW;

Rated Assembly Inspection

John Borns

Partial

Friday, January 18, 2013

Partial Correction

1 MISC FOLLOWING COMPONENTS OF PASSENGER ELEVATOR

FRONTS OK TO COVER WHEN READY:

1ST FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE

LAYER 5/8" TYPE X GWB FIRE-CAULKED;

2ND FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

3RD FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED;

4TH FLOOR: 2ND FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

5TH FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED

Partial Correction 2 MISC

FOLLOWING COMPONENTS OF 1ST FLOOR FREIGHT ELEVATOR SHAFT OK TO COVER WHEN READY: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB

Partial Correction 3 MISC

FOLLOWING COMPONENTS OF FREIGHT ELEVATOR FRONTS OK TO COVER WHEN READY:

2ND FLOOR THROUGH 5TH FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB

Comments: